



1. SURFACE OF DOOR WHERE EXIT DEVICE IS TO BE APPLIED MUST BE FLUSHED
2. SEE MASTER SHEET FOR AREAS REQUIRING REINFORCEMENTS
3. SEE STRIKE TEMPLATE FOR TOP AND BOTTOM STRIKES
4. WE RECOMMEND THAT ALL TAPPED HOLES BE DRILLED AND TAPPED IN FIELD
5. TOLERANCE ON ALL DIMENSIONS ± 1/64"

NOTE: All Fire Rated applications are required to use the sex bolts, and Auxillary Flushbolts.



**LBRF9860V LESS BOTTOM ROD
FIRE-RATED EXIT DEVICE**

LBRF9860V

