

Notified Body No. 2812

# **Certificate of Constancy of Performance**

## 2812-CPR-AD8003

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

### **CRP EU8320 Concealed Door Closer**

Intended use: For use on fire rated single leaf and double leaf doors

Essential characteristics	Performance	Harmonised technical specification
Mechanical Test Ref's : 189820 & 189820/C		
Fire Test Ref's : WF 321045		
Self-closing		
5.2.1 General		
5.2.2 Durability	500,000 test cycles	
5.2.3 Closing moment	Pass size 3	
5.2.4 Opening moment	Pass size 3	
5.2.5 Efficiency	> 55% size 3	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 3 > 105°	
5.2.8 Overload performance	Pass	
5.2.9 Temp dependence	-15°C to +40°C	
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	EN 1154:1996 /
5.2.12 Latch control	Pass	A1:2002 / AC:2006
5.2.13 Back check (optional)	NPD	
5.2.14 Delayed closing (optional)	NPD	
5.2.15 Adjustable closing force	NPD	
(optional)		
5.2.16 Zero position (double action	NPD	
door closers only)		
5.2.18 Fire/smoke door suitability	Pass	<i>*</i>
Durability of Self Closing		
5.2.2 Durability	500,000 test cycles	
5.2.17.1 Corrosion	Grade 3 (96 hours)	
5.2.17.2 Corrosion	Pass	
Dangerous Substances	Pass: the materials in the door closer do not	
Annex ZA3	contain or release any dangerous substances in	
	excess of the maximum levels specified in existing	
	European material standards or any national	
	regulations	







Notified Body No. 2812

#### **Certificate of Constancy of Performance**

#### 2812-CPR-AD8003

Placed on the market under the name of:

#### CAL-ROYAL PRODUCTS INC 6605 FLOTILLA ST COMMERCE CALIFORNIA 90040 USA

and produced in the manufacturing plant:

#### E013982-4

#### This is coded format, and the information is held by the Notified Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard:

#### EN 1154:1996 / A1:2002 / AC:2006

Under System (1+ or 1) for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **21/02/2023** and reissued on **10/10/2024** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: 13/12/2026

ERO Project Reference: ERO 034621 P2302

Et

Pascal Coget General Manager - European Certification



CSF408-NL 7.0